

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212985
Address: 1928 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Mitchell Schwarz	Not Ready	Tuesday, March 15, 2022

Corrective Action Required:

1	Misc	-ground service to ufer (connect GEC to middle grounded bus bar or supply approved jumper to middle grounded bus bar)
---	------	--

Corrective Action Required:

2	Misc	The grounding electrode conductor shall be connected to the grounded service conductor, in accordance with 250.24(A) (1) or 250.24(A) (4) of the NEC.
---	------	---

Comments: