

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215365
Address: 451 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|-----------------|----------|-------------------------|
| Occupancy Inspection - Codes Commercial | Michael Harkins | Failed | Tuesday, March 15, 2022 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | Pay not ready fees Exam B cover plate receptacle under window Provide GFCI protection dishwasher break room Secure switch & provide cover plate outside mechanical room Service panel covers with doors Provide GFCI protection at mop sink (soiled lab) Provide anti siphon device at mop sink Provide GFCI protection south side Lab 2 Provide guardrail at retaining wall |
|---|------|--|

: OK TO STOCK & TRAIN :

Comments: