

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215300
Address: 500 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Michael Harkins	Failed	Wednesday, March 16, 2022

Corrective Action Required:

1	Miscellaneous Correction	EXTERIOR WALL SHEATHING NAILING PATTERN NAIL PER PLAN WALL SHEATHING AND NAILING SCHEDULE Nail corner of electrical room near back door per plan Nail below front window Nail west side right of window Nail West side near water line
---	--------------------------	---

Comments: