

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211881  
Address: 2362 SW HICKORY LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Diana Johnson	Partial	Tuesday, March 15, 2022

Informational:

1 Misc

On Tuesday 3.15.2022 I performed a sidewalk inspection and pass the subgrade to pour concrete. There was existing handicap ramp and existing curb inlet/storm box. Expansion joints were recommended for storm box because of wall thickness and doweling was recommended for existing h/c ramp pad.

**Comments:**