

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212003
Address: 528 SE CARTER RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, March 16, 2022

Corrective Action Required:

1	Misc	-add stud shoe DWV kitchen exterior wall -secure all vertical DWV 2" or less at mid point- see 2nd floor
---	------	---

****OK TO INSULATE****

Comments: