CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

| Permit #: | PRRES20211621 |
|------------------|--------------------------------------------|
| Address: | 2333 SW OLD PORT RD, LEES SUMMIT, MO 64082 |
| Inspected On: | Wednesday, March 16, 2022 |
| Inspected By: | Mitchell Schwarz |
| Expiration Date: | 4/4/2022 12:00:00 AM |

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------------------|------------------|------------------|------------------------------|
| Occupancy Inspection - Codes Residential | Mitchell Schwarz | Temporary C of O | Wednesday, March 16, 2022 |

Corrective Action Required:

| 1 | Misc | TCO UNTIL 4/4/22 -sod -check water meter and siding from grade at time of final grade and sod. -seal top of meter can, lights, and all other exterior penetrations -(2) 1/2" through bolts required at deck post to beam connections -Address pending driveway inspection |
|---|------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| | | all interior has been checked and is good |