

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213121
Address: 3105 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Mitchell Schwarz	Failed	Wednesday, March 16, 2022

Corrective Action Required:

1	DCM1 ESC REQUIRED NO FURTHER INSP	EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE. Mitchell Schwarz 03/09/2022 10:16 AM
---	---	---

Corrective Action Required:

2	Misc	EROSION CONTROL NOT IN COMPLIANCE MAINTAIN EROSION CONTROL -GRAVEL FILTER NEEDS MAINTAINED -CLEAN UP STREET -CLEAN AND MAINTAIN STORM INLET
---	------	--

Corrective Action Required:

3	DCM5 ESC INSP DENIED	REQUESTED INSPECTION(S) DENIED DUE TO DEFICIENT EROSION CONTROL INSTALLATION. Mitchell Schwarz 03/16/2022 1:46 PM
---	-------------------------	---

Comments: