

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211820  
Address: 1867 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Adam Nacke	Partial	Wednesday, March 16, 2022

Informational:  
1 Misc 12/30/21 Thursday  
Sidewalk forms and materials passed pre-inspection.

Informational:  
2 Miscellaneous 3-16-22 AN sidewalk to the left of the driveway was over 2%  
Correction

Informational:  
3 Misc 3-16-22 AN forms are in place and aggregate is present and compacted. They  
fixed part that was over 2%

**Comments:**