

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211881
Address: 2362 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Not Ready	Thursday, March 17, 2022

Corrective Action Required:

1	Misc	-Final grade and sod -complete gutters -down spouts and sump pump discharge to extend 36" from foundation -supply attic access panel -complete driveway and sidewalk inspections pending -address footing poured without passed inspection
---	------	---

Comments: