

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212204
Address: 4736 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Thursday, March 17, 2022

Corrective Action Required:

1	Misc	-Ground service to ufer rebar with listed clamp for aluminum conductor. Use the listed aluminum clamp and flip the bottom half around for tight connection to rebar
---	------	---

Comments: