

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213784  
Address: 2617 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, March 17, 2022

Corrective Action Required:

1	Misc	inspection denied, erosion control not in compliance
		<ul style="list-style-type: none"><li>-fire block south end furr down in garage</li><li>-connect GEC to middle grounded bus bar</li><li>-Secure fire blocking insulation in place</li><li>-fire block north basement wall</li><li>-complete dryer vent wall and fire block</li><li>-complete attic access</li><li>-add support for ridge above living room/kitchen wall</li><li>-receptacle required right of back door wall space greater than 2'</li></ul>

Comments: