

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213013
Address: 2613 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------------|------------------|----------|--------------------------|
| Electrical Service Inspection | Mitchell Schwarz | Failed | Thursday, March 17, 2022 |

Corrective Action Required:
1 Misc inspection denied, erosion control not in compliance
-connect GEC to middle grounded bus bar

Comments: