

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20212025
Address: 1808 SW RIVER RUN DR, LEES SUMMIT, MO 64082
Inspected On: Thursday, March 17, 2022
Inspected By: Mitchell Schwarz
Expiration Date: 4/18/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Temporary C of O	Thursday, March 17, 2022

Corrective Action Required:

1	Misc	TCO until 4/18/22 -Final grade and sod -(2) 1/2" through bolts at all deck post to beam connections -check water meter at time of final grade and sod
---	------	--