


[mike@skeensconsulting.com](mailto:mike@skeensconsulting.com)

423 N. Winnebago Drive Ph.: (816) 806-9719  
Lake Winnebago, MO 64034

Date: March 15, 2022  
To: Building Codes Official  
City of Lee's Summit, MO  
220 SE Green Street  
Lee's Summit, Missouri 64063  
Re: Structural Garage Slab Inspection  
2143 NW Killarney Lane  
Reserve Woodside Ridge Lot MC132  
Lee's Summit, MO 64081



Dear Codes Official,

This letter is in regards to a job site inspection for a structural garage slab at 2143 NW Killarney Lane in the Reserve Woodside Ridge subdivision.

Upon arrival at the site the metal composite steel decking was in place and secured. Secondary wall supports were constructed at the middle span to reduce deflection from the loading of the concrete placement and for concrete surfaces to cure.

The reinforcing steel was positioned and it appeared to be of correct size and spacing. Bar chair supports were also in place. Added reinforcing steel was also placed over the steel beam supports.

Some of the concrete placement was observed. Placement was done by direct chute placement. Placement progressed well and extra effort was made to insure proper slope of the finished surface

If you have any questions regarding these items please feel free to contact me.

Respectfully,

Michael H. Skeens, P.E.

