

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213828
Address: 4821 NE FREEHOLD CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Friday, March 18, 2022

Corrective Action Required:

1	Misc	-Support the outer deck joists with proper hanger; lag ledger board to rim band
		-Deck wall covered prior to inspection. Expose everything **secure wiring per code. Secure away from fireplace box

**OK TO ROCK

**1/31/22-THIS IS A 2ND ALL-ROUGH INSPECTION. NOT READY FEE WILL BE ASSESSED FOR EACH SUBSEQUENT FAILED INSPECTION

**2/10/22-NOT READY FEE ASSESSED

Comments: