

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20210753
Address: 213 NW AMBERSHAM DR, LEES SUMMIT, MO 64081
Inspected On: Friday, March 18, 2022
Inspected By: Michael Harkins
Expiration Date: 4/15/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Temporary C of O	Friday, March 18, 2022

Corrective Action Required:

1	Miscellaneous Correction	PAY NOT READY FEE OBTAIN LAWN IRRIGATION PERMIT & SUBMIT BACKFLOW CERTIFICATION PROVIDE SOD PROVIDE SPLASH BLOCKS SUMP SHALL DISCHARGE 36" FROM FOUNDATION
---	-----------------------------	---

: SOD NOT DONE EXTEND TCO TO 4/15/22 :
Michael Harkins 03/18/2022 10:35 AM