

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210438
Address: 2048 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Michael Harkins	Failed	Friday, March 18, 2022

Corrective Action Required:

1	DCM5 ESC INSP DENIED	**9-22-21 Inspection denied due to lack of erosion control-Maintain gravel filter, silt fence at perimeter and clean trash and debris from site before further inspections
---	-------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

REQUESTED INSPECTION(S) DENIED DUE TO DEFICIENT EROSION CONTROL INSTALLATION.

Corrective Action Required:

2	DCM2 ESC DEFICIENT INSTALLATION	DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.
---	---------------------------------------	---------------------------------------------------------------------------------------------------------

MAINTAIN SILT FENCE UNTIL SOD COMPLETE

Comments: