

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211881  
Address: 2362 SW HICKORY LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Friday, March 18, 2022

Corrective Action Required:

1	Misc	-Final grade and sod -complete gutters -down spouts and sump pump discharge to extend 36" from foundation -complete driveway and sidewalk inspections pending -address footing poured without passed inspection
---	------	---

**Comments:**