



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20210427	Date:	March 20, 2022
Project Title:	PETSUITES OF AMERICA	Applicant:	
Location:			
250 NW MCNARY CT, LEES SUMMIT, MO 64086		PALMER ELECTRIC CO	
Type of Work:		6600 ROYAL ST, BLDG B	
Occupancy Group:	B	PLEASANT VALLEY, MO 64068	
Description:	NEW BUILDING PET BOARDING		
AND DAYCARE FACILITY WITH SPACE FOR FUTURE VET		Primary: (816) 479-2587	
CLINIC (PRCOM20211647)			
Construction Type:	Type IIB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2018 IFC 904.4.2- Alarm testing. Notification appliances, connections to fire alarm systems, and connections to approved supervising stations shall be tested in accordance with this section and Section 907 to verify proper operation.

Coordinate alarm testing with the sprinkler flow testing. Call (816) 969-1300 to schedule a test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.