CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211738

Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Pavement-Surface Eric Sharp Partial Monday, March 21,

2022

Informational:

1 Misc Shawn's crew put in ~800 tons of base, doing single lift on parking areas and

two lifts on drive lanes. Intertek PSI was on site doing compaction testing.

3/16/22 ES

Comments: