

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213630
Address: 433 NW KAYLEA CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|----------|------------------------|
| All Rough Inspection - Residential | Shawn Hoffman | Failed | Monday, March 21, 2022 |

Corrective Action Required:

1 Misc

- complete nailing for PFH portal frame
- Address broken truss at garage/entry
- Provide nuts and tighten anchor bolts in basement
- Finnish DWV under bedroom 1 shower
- correct excessive slack in LIB bedroom 1
- Complete solid blocking from truss space wall at entry, great room

Comments: