CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20211738Address:2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:	
Water Line - Construction Inspection		Ronald Paynter	Passed	Monday, March 21, 2022	
Informational:					
1 Mi	lisc	for the under slab plumbi	nstalled the 6" fire line and ng. They will be pouring th Harkins will look at this as	e thrust blocks at	
Informational:					
2 Mi	lisc	Don's crew from Larry Bai line. RP 8-16-21	r Excavating laid 80 feet of (5 inch C 900 for. The fire	
Informational:					
3 Misc Informational:		They laid another 80 feet of 6 inch C 900 for the fire line. RP 8-17-21			
4 Mi	lisc		nch fire line to the building. rust blocks for the 90 degree		
Informational:					
5 Mi	lisc	-	d to the job site and conne he top will need to be pain -21		
Informational:					
6 Mi Informationa	lisc al:	Fire hydrant was set and t	thrust blocks were poured.	RP 8-20-21	
7 Mi	lisc	Don's crew from Bair dug 8-30-21	up and formed the floor fo	r the back flow vault. RP	

Informatio	onal:			
8	Misc	They poured the floor for the back flow vault. They also poured thrust and straddle blocks for the water line going into the vault. RP 9-1-21		
Informational:				
9	Misc	They got the back-flow vault set today. RP 9-2-21		
Corrective Action Required:				
10	Misc	Still need to mark fire hydrant as private (silver top). RP 2-15-22		
Informatio	onal:			
11	Misc	Fire hydrant has been marked as private. RP 3-21-22		

Comments: