

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215211

Address: 4023 NE SAGAMORE DR, LEES SUMMIT, MO 640644025 NE SAGAMORE DR, LEES SUMMIT, MO
640644027 NE SAGAMORE DR, LEES SUMMIT, MO 640644021 NE SAGAMORE DR, LEES
SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - R	Khanh Nguyen	Failed	Monday, March 21, 2022

Corrective Action Required:

1	Misc	**DO NOT COVER SEWER OUTSIDE UNIT 4021 AND 4023. CURRENTLY, SEWER FROM 4021 IS CONNECTED TO THE SAME SEWER STUB OF 4023. CONTACT WATER DEPARTMENT/FIELD SERVICE ENGINEER REGARDING MISSING SEWER STUB FOR UNIT 4021
---	------	--

Comments: