

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20211738  
Address: 2061 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Aggregate Base</b>	Ronald Paynter	Passed	Monday, March 21, 2022

Informational:		
1	Misc	KAW Valley rolled out Tenax 302 geo grid and covered it with 6 inches of APWA Type 3 rock. So far they've laid out 115 tons of AB3. RP 11-9-21
Informational:		
2	Misc	Kaw Valley rolled out more Tenax 302 and covered it with more AB3 rock. RP 11-17-21
Informational:		
3	Misc	Kaw Valley still rolling on geogrid and laying down AB3 for the parking lot subgrade. RP 2-15-22

**Comments:**