



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

**Prevention Division
(816)969-1300**

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20221029	Date: March 21, 2022
Project Title:	SUMMIT WOODS WHITE BOX	Applicant:
Location:		ABSOLUTE FIRE INC
Type of Work:		13906 CENTURY LN
Occupancy Group:	UC	GRANDVIEW, MO 64030
Description:	WHITE BOX FOR FUTURE TENANT	
Construction Type:	Type IIB (Unprotected)	<NO CONTACT NAME AVAILABLE>
Map Page:		<NO CONTACT INFORMATION AVAILABLE>

Primary: (816) 737-9991

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action required- Call for a hydrostatic test, followed by a flow test once after the alarms are connected. Call (816) 969-1300 to schedule both tests.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.