

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213123
Address: 130 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Shawn Hoffman	Passed	Tuesday, March 22, 2022

Corrective Action Required:	
1	Miscellaneous Correction
	CONNECT & SECURE GAS LINE AT FIREPLACE PROVIDE MIN 10 PSI FOR 15 MINUTES

Comments: