

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215028  
Address: 2601 NE MCBAINE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 1</b>	Adam Nacke	Passed	Tuesday, March 22, 2022

Informational:  
1 Misc 3-16-22 AN did first bac-t test on 3-15-22 at 12pm  
Informational:  
2 Misc 3-22-22 AN first water sample passed. Doc attached

**Comments:**