

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216532
Address: 1812 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|---------------|----------|------------------------|
| Underslab Plumbing Inspection - Residential | Shawn Hoffman | Passed | Friday, March 04, 2022 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | - No access to basement floor -lid covering connections - compression joint not conforming with ASTM D2949 or ASTM F1488 |
|---|------|--|

Comments: