

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210734
Address: 1514 SW HEARTWOOD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------|---------------|----------|------------------------|
| Sewer Service Inspection - R | Steve Robbins | Failed | Monday, March 07, 2022 |

Corrective Action Required:

| | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | It appears that the MH (4511) in the back of the lot has been hit, there is also debris in the line. Contractor needs to make corrections to the MH. |
|---|--------------------------|--|

Comments: