

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210399
Address: 4524 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Deck Final Inspection - Residential	Shawn Hoffman	Failed	Tuesday, March 22, 2022

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | - Provide corrections for deck ledger patio side
- Provide 2 @ 1/2" through bolts at deck at the beam to post connections |
|---|------|--|

Comments: