

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212683
Address: 1033 SW REDBUCK CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Shawn Hoffman	Failed	Wednesday, March 23, 2022

Corrective Action Required:

1	DCM2 ESC	- Remove debris from street corner
	DEFICIENT	- repair silt fence
	INSTALLATION	

Comments: