CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211709

Address: 2357 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Mitchell Schwarz Failed Wednesday, March 23,

Residential 2022

Corrective Action Required:

1 Misc -fire stop garage to stairway dead space (seal all gaps

-uncover covered deck for inspection

-provide (2) 1/2" through bolts at deck post to beam connections

-address over notched studs west basement wall

-seal penetrations in vertical to horizontal fire blocking

-provide fire blocking at furred down ends and beam ends in basement -basement bearing wall and stud where top plate cut for return air (and

protect NM at this location)

Comments: