

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220820  
Address: 813 NE RICE RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Khanh Nguyen	Failed	Wednesday, March 23, 2022

**Corrective Action Required:**

1	Misc	-Bond all metal boxes -Support boxes -Cannot use s-tee fittings at vertical-horizontal or horizontal-horizontal drainage connections -Above-ceiling NM circuits to wall receptacles or light outlets shall be replaced with MC or other approved wiring methods. Secure wiring within 12" of box
---	------	---

**Comments:**