

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214074  
Address: 420 NW KAYLEA CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Not Ready	Wednesday, March 23, 2022

Corrective Action Required:

1	Misc	-Install H2.5 or equivalent at all hip trusses throughout ( TRUSS SCREWS TO BE INSTALLED THROUGH A DOUBLE TOP PLATE SOME ONLY IN TOP PLATE )  - seal all top and bottom plate penetrations ( not done 3/23/22 dwv master vanity, sliding glass door deck )  -fireblock vertical to horizontal at furred down soffit ends at finished basement ( 3/23/22 not done bed 3 & 4 ) ( seal gap in fire block at top plate wall with service panel basement )
---	------	--

**Comments:**