

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213148
Address: 508 NW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Wednesday, March 23, 2022

Corrective Action Required:

1	Miscellaneous Correction	Address notched gable trusses notched at top cord A1G & A1GA Address notched truss at stairway A1B Truss screws shall run through double top plate throughout Nail double truss bed 3 Provide protection plate NM hall at powder room Nail intersecting wall corners per code Tighten anchor bolts garage Provide anchor bolts within 12" of end of plate breaks garage Strap corner top plate both sides of fireplace no overlap Strap corners dining room no overlap Protect pex line bath linen closet basement Address cut floor joist near service panel
---	--------------------------	--

Comments: