

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20215290
Address: 2200 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|----------------|----------|---------------------------|
| Erosion Sediment Control (ESC) Inspection | Ronald Paynter | Partial | Wednesday, March 23, 2022 |

Informational:
1 Misc No erosion issues to report on the job site today. RP 3-23-22

Comments: