



WATER UTILITIES LEE'S SUMMIT

220 SE GREEN ST, LEE'S SUMMIT, MO 64064
PHONE: (816) 969-1930 FAX: (816) 969-1935
EMAIL: backflow@cityofls.net WEB: lswater.net

BACKFLOW PREVENTION ASSEMBLY TEST DATA AND MAINTENANCE REPORT

CUSTOMER TRUMARK HOMES							
SERVICE ADDRESS 125 NW AMBERSHAM							
LOCATION OF BACKFLOW ASSEMBLY ON PROPERTY Basement Area							
DATE OF TEST 10-26-2021		TIME 10:00		S.A.M. <input checked="" type="checkbox"/> P.M. <input type="checkbox"/>		SUPPLY PRESSURE 75 LBS	
				AIR GAP (2 X SUPPLY DIAMETER) SUPPLY 1/4 IN. GAP 1/4 IN.		<input type="checkbox"/> PASS <input type="checkbox"/> FAIL	
TYPE OF ASSEMBLY <input checked="" type="checkbox"/> DCDA (DETECTOR) <input type="checkbox"/> RPDA (DETECTOR) <input type="checkbox"/> PVB* (SEE BOTTOM OF FORM)		MANUFACTURER FEBCO		MODEL 850		SIZE 3/4	
HEIGHT OFF FLOOR 5 FT 0 IN		PROTECTION FROM: FREEZING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO FLOODING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		SUPPLY SOURCE: <input checked="" type="checkbox"/> PUBLIC POTABLE WATER <input type="checkbox"/> NON-POTABLE WATER (e.g., LAKE) <input type="checkbox"/> BOTH		NEW INSTALLATION <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	
INITIAL TEST REDUCED PRESSURE PRINCIPLE ASSEMBLY:				FINAL TEST AFTER REPAIR REDUCED PRESSURE PRINCIPLE ASSEMBLY:			
PASSED FAILED RELIEF VALVE OPENED AT ____ PSID (2 PSID or more) <input type="checkbox"/> <input type="checkbox"/> 2ND CHECK held backpressure <input type="checkbox"/> <input type="checkbox"/> NO. 2 SHUTOFF VALVE leak tight <input type="checkbox"/> <input type="checkbox"/> 1ST CHECK held in direction of flow ____ PSID (5 PSID or more) <input type="checkbox"/> <input type="checkbox"/> DIFFERENCE (1st check - relief) ____ PSID (3 PSID or more) <input type="checkbox"/> <input type="checkbox"/> NOTE: Failure of any of the above items, requires repair.				PASSED FAILED RELIEF VALVE OPENED AT ____ PSID (2 PSID or more) <input type="checkbox"/> <input type="checkbox"/> 2ND CHECK held backpressure <input type="checkbox"/> <input type="checkbox"/> NO. 2 SHUTOFF VALVE leak tight <input type="checkbox"/> <input type="checkbox"/> 1ST CHECK held in direction of flow ____ PSID (5 PSID or more) <input type="checkbox"/> <input type="checkbox"/> DIFFERENCE (1st check - relief) ____ PSID (3 PSID or more) <input type="checkbox"/> <input type="checkbox"/> NOTE: Failure of any of the above items, requires repair.			
INITIAL TEST DOUBLE CHECK VAVLE ASSEMBLY:				FINAL TEST AFTER REPAIR DOUBLE CHECK VAVLE ASSEMBLY:			
PASSED FAILED 1ST CHECK held in direction of flow 2.7 PSID (1 PSID or more) <input checked="" type="checkbox"/> <input type="checkbox"/> 2ND CHECK held backpressure <input checked="" type="checkbox"/> <input type="checkbox"/> 2ND CHECK held in direction of flow 2.4 PSID (1 PSID or more) <input checked="" type="checkbox"/> <input type="checkbox"/> NO. 2 SHUTOFF VALVE leak tight <input checked="" type="checkbox"/> <input type="checkbox"/> NOTE: Failure of any of the above items, requires repair.				PASSED FAILED 1ST CHECK held in direction of flow ____ PSID (1 PSID or more) <input type="checkbox"/> <input type="checkbox"/> 2ND CHECK held backpressure <input type="checkbox"/> <input type="checkbox"/> 2ND CHECK held in direction of flow ____ PSID (1 PSID or more) <input type="checkbox"/> <input type="checkbox"/> NO. 2 SHUTOFF VALVE leak tight <input type="checkbox"/> <input type="checkbox"/> NOTE: Failure of any of the above items, requires repair.			
APPLICATION:		COMMENTS					
<input type="checkbox"/> COMMERCIAL <input checked="" type="checkbox"/> IRRIGATION <input type="checkbox"/> FIRE LINE <input type="checkbox"/> FIRE LINE BY-PASS **METER # _____ **METER READ _____ <input type="checkbox"/> POINT OF USE		TESTED BACKSHOW WORKING CORRECTLY					
THE ABOVE REPORT IS CERTIFIED TO BE TRUE, ACCURATE AND COMPLETE							
TESTED BY (PRINT) DAVID J COSTER		(SIGNATURE) 		REPAIRED BY (PRINT)		(SIGNATURE)	
COMPANY Line Valley Lawn & Son Boape		FINAL TEST BY (PRINT)		(SIGNATURE)		DATE OF REPAIR	
MISSOURI CERTIFICATION NUMBER 34-11206		EXPIRATION DATE 9-30-2022		OWNER OR OWNER'S REPRESENTATIVE		DATE	
* If an existing PVB is beyond repair and needs replacement, it should be replaced by a DC or RP to meet current State and City regulations. New PVB installations or replacements are not permitted. ** METER # and METER READ for the fire line by-pass meter on detector assemblies are required. Missouri State Regulation 10 CSR 60-11-010(6)(E) requires testers to report results of tests and inspections to the customer and water supplier.							