

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20213431  
Address: 420 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Shawn Hoffman	Partial	Thursday, March 24, 2022

**Corrective Action Required:**

1	Misc	-Inside wall 1 hour fire rated inspected
		- 3 stairways inside fire walls inspected
		Stairways
		- (A) screws on stairway inspected fire blocking needed
		-(B) across from landing needs addressed
		-(C) screws on back side of stairs needs corner adressed

**Comments:**