

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220431

Address: 420 SW LONGVIEW BLVD, Unit:116, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Shawn Hoffman	Failed	Thursday, March 24, 2022

Corrective Action Required:

1	Misc	Unit (A) - no pressure - trap wiew cannot rise then fall in s pattern, lower traps.
---	------	---

Comments: