

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220499  
Address: 1211 NE RICE RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Khanh Nguyen	Partial	Thursday, March 24, 2022

Corrective Action Required:

1	Misc	-Support pump 2" pvc at every 4 ft or less and slope toward drain -Support pex water lines every 32" or less
---	------	---

\*\*ok to cover wall and underslab plumbing

**Comments:**