

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212440
Address: 1828 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, March 24, 2022

Corrective Action Required:

1 Misc

INSPECTION DENIED

ADDRESS EROSION CONTROL AT REAR OF LOT, SILT FENCE DOWN AND THERE IS MUD IN ALLEY
REPAIR AND MATAIN SILT FENCE CLEAN ALL MUD FROM ALLEY

Comments: