

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212440  
Address: 1828 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Patrick Schonfeldt	Failed	Thursday, March 24, 2022

Corrective Action Required:

1	Misc	INSPECTION DENIED
---	------	-------------------

ADDRESS EROSION CONTROL AT REAR OF LOT, SILT FENCE DOWN AND THERE IS MUD IN ALLEY  
REPAIR AND MATAIN SILT FENCE CLEAN ALL MUD FROM ALLEY

**Comments:**