

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212068
Address: 3213 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, March 25, 2022

Corrective Action Required:

- | | | |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none">- front porch not inspected, remove sheeting enough to see framing- Patio roof not inspected, remove sheeting to provide access to framing- Provide anchor bolts PFH portal frame and 2"x2"x3/16" washer- Nail all exterior corners through out to code- Replace straps at top plate laundry DWV to Boca plate- Strap all DWV vertical under 2" diameter- Provide Boca plate at top plate, DWV bedroom 2 closet-Boca plates on DWV master bedroom entry- Fire block penetrations floor hall to master- Fire block top plate penetration master bedroom at stairs- Shim studs supporting truss great room at hall, exterior wall |
|---|--------------------------|---|

Comments: