

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212715
Address: 4717 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Khanh Nguyen	Not Ready	Friday, March 25, 2022

Corrective Action Required:

1	Misc	Provide min ten psi pressure
---	------	------------------------------

****3/25-MIN TEN PSI PRESSURE STILL NOT PROVIDED FOR TESTING. NOT READY
FEE ASSESSED**

Comments: