

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212194
Address: 4721 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, March 28, 2022

Corrective Action Required:

1	Misc	-Protect water lines at master shower
		-The vertical fire blocking at rear bedroom exceed way more than ten ft
		-Master bath tub vent connection cannot be below trap weir **lower the trap down to the wet-vented 3" drain level or install individual vent for the tub trap

**OK TO INSULATE

Comments: