

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212634
Address: 3205 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, March 28, 2022

Corrective Action Required:

1	Misc	Inspection denied address gravel filter Mitchell Schwarz 03/28/2022 10:08 AM
		-Maintain gravel filter before further inspections -hold downs at gt truss above laundry -anchor all steel columns in basement -address joist notched above steel beam in basement

Comments: