

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214074
Address: 420 NW KAYLEA CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Monday, March 28, 2022

Corrective Action Required:

1	Misc	-Install H2.5 or equivalent at all hip trusses throughout (TRUSS SCREWS TO BE INSTALLED THROUGH A DOUBLE TOP PLATE SOME ONLY IN TOP PLATE) : garage not done screws only catch top plate 3/28/22 : -fireblock vertical to horizontal at furred down soffit ends at finished basement (3/23/22 not done bed 3 & 4) (seal gap in fire block at top plate wall with service panel basement) : Per 2018 IRC R302.11 Fireblocking : (not done 3/28/22)
---	------	---

OK TO INSULATE

Comments: