

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215017  
Address: 126 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Michael Harkins	Failed	Monday, March 28, 2022

Corrective Action Required:

1	Miscellaneous Correction	(3) PIERS 18 X 22 PIERS SHALL EXTEND BELOW THE FROST LINE MIN DEPTH OF 36" BELOW GRADE PER PLAN COLUMN & PIER SCHEDULE SHEET A2 : BREAK IT OF PROVIDE ENGINEERS LETTER :
---	--------------------------	--

**Comments:**