

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212831
Address: 900 NE DEERBROOK ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Partial	Monday, March 28, 2022

Informational:
1 Misc

ABOVE-CEILING OK BELOW:
-MEN'S LOCKER & RESTROOM

WOMEN'S LOCKER ROOM: SUPPORT LOW VOLTAGE CABLES OFF CEILING GRIDS
IN A NEAT AND WORKMAN-LIKE MANNER

Comments: