

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214283
Address: 1808 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Not Ready	Monday, March 28, 2022

Corrective Action Required:

2 Misc

INSPECTION DENIED

- ADDRESS EROSION CONTROL AT FRONT OF LOT, MAINTAIN SILT FENCE
- NO FIREBLOCKING HAS BEEN PERFORMED THROUGHOUT, THIS SHOULD BE DONE BEFORE SCHEDULING ROUGH INSPECTION

Comments: